



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT



From
The District fire officer,
Karimnagar District.

To,
ENUGANTI PRASAD RAO,
H.NO:7-1-746,
MANKAMMATHOTA,
KARIMNAGAR.,

Ack. No. **682580002026** Dated: **21/07/2026**

Sir,
Sub: Telangana Fire, Disaster Response, Emergency & Civil Defence Department —Karimnagar District. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **M/S. EXPLORICA SCHOOL ARAVINDA EDUCATIONAL SOCIETY, MPL NO: 2-10-1437, JYOTHINAGAR, KARIMNAGAR DIST./-Karimnagar/Karimnagar/Karimnagar**, – Regarding.



Ref: 1. Acknowledgement No **682580002026**
2. This Office NOC for Occupancy Ack/RC No. **RC.NO:415/B1/2016** dt. **21/07/2026**
3. Non Multi storeyed Building Inspection Committee Report,.
Ack. No. **682580002026**, dt. **21/07/2026**

1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **M/S. EXPLORICA SCHOOL ARAVINDA EDUCATIONAL SOCIETY, MPL NO: 2-10-1437, JYOTHINAGAR, KARIMNAGAR DIST./-Karimnagar/Karimnagar/Karimnagar**

2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Cellars,1 Ground, 3 Floors**, with a height of **14.50** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy .

3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Cellars,1 Ground, 3 Floors**, with a height of **14.50** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy

4) Open Spaces: The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	0.00	0.00
2	South	0.00	0.00
3	East	1.10	1.10
4	West	0.00	0.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	2.50	2.50
2	Entry Gate Head Clearance	5.00	5.00
3	Exit Gate Width	0.00	0
4	Exit Gate Head Clearance	0.00	0

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	15.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

Head Mistress
Explorica Upper Primary School
Karimnagar.
Page 1/4



GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT



As per the physical inspection conducted by the DFO and satisfactory provision of Fire safety measures, the Renewal file is here with approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **M/S. EXPLORICA SCHOOL ARAVINDA EDUCATIONAL SOCIETY, MPL NO: 2-10-1437, JYOTHINAGAR, KARIMNAGAR DIST./-Karimnagar/Karimnagar/Karimnagar**

with a height of **14.50** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five Years from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five Years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Signed By : Mr. M. Srinivas Reddy
Designation : District Fire Officer , Karimnagar
Date : 21-07-2026
Karimnagar District.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

Shamsh
Head Mistress
Explorica Upper Primary School
Karimnagar.